

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

| | |
|--|---|
| School District: | 22 - Vernon |
| School Name: | BX Elementary |
| REQUIREMENT: Regular inspection and maintenance of HVAC systems | Yes/No: Yes |
| | Date of last inspection: 2022-08-22 |
| | Date of next inspection: 2022-11-21 |
| | Date and type of most recent maintenance: Filter Replacement, controls verification, amperage check, and other preventative maintenance procedures. 3rd Party airflow and system evaluation underway |
| RECOMMENDATION: Increase supply of outside air | Yes/No: Yes |
| | Detail: Fresh Air flow increased 100% |
| RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible | Yes/No: No |
| | Detail (Including filter grade): Tackified Merv 9 filters used throughout the district Some Merv 13 in New RTU |
| RECOMMENDATION: Use other air cleaning or treatment technologies | Yes/No: Yes |
| | Detail: GPS ionization system installed. |
| RECOMMENDATION: Manage energy use and air distribution through building automation control systems | Yes/No: Yes |
| | Detail: Upgraded DDC system. Upgraded/Replaced |
| Other Relevant Information: | CO2 set point lowered to 750 ppm Expanded HVAC hours 6am to 9pm |
| District Contact for any Questions: | Name: Archie Stogianos |
| | Phone Number: 250-549-9210 |
| | Email: astogianos@sd22.bc.ca |

